

6.4.2 水再利用測量 Water reuse measurement

| | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 | 2016 | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 |
|---|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|--------|--------|--------|
| 總用水量 total volume of water used(M ³) | 177,793 | 156,407 | 141,964 | 146,284 | 153,640 | 145,798 | 139,353 | 125,950 | 110,002 | 109,542 | 98,505 | 74,975 | 83,369 |
| 雨水回收量 rainwater recycling(M ³) | 12,543 | 19,571 | 28,892 | 28,116 | 31,005 | 30,170 | 26,209 | 28,669 | 29,873 | 31,433 | 17,580 | 14,355 | 15,677 |
| 中水回收量 Recycled water (M ³) | 64,355 | 40,618 | 42,417 | 33,087 | 42,629 | 49,506 | 39,065 | 45,578 | 45,254 | 45,077 | 49,144 | 40,896 | 38,880 |
| 回收比率 Recovery rate (%) | 30.20% | 27.80% | 33.40% | 29.50% | 32.40% | 35.30% | 32.00% | 37.10% | 40.60% | 41.10% | 40.40% | 42.2% | 39.6% |